# LED Office Lum./LED办公灯具


## RC099V

Mounting instruction/ 安装说明


RC099V-C029

GB 7000 IEC 60598 220V-240V~ 50/60 Hz

| Product Type 产品型号 | Lumen 流明 | Power 系统功率 | LEDs 颗粒数 | Dimension 尺寸L*W*H（mm） | CCT 色温 | kg |
|---|---|---|---|---|---|---|
| RC099V LED26S W60L60 | 2600 | 29W | 12*12LEDs | 597*597*75 | 4000K/6500K | 2.5 |
| RC099V LED26S W30L120 | 2600 | 29W | 6*24LEDs | 297*1197*75 | | 2.5 |
| RC099V LED26S W60L60 SUS | 2600 | 29W | 12*12LEDs | 603*603*75 | | 2.6 |
| RC099V LED26S W30L120 SUS | 2600 | 29W | 6*24LEDs | 303*1203*75 | | 2.6 |
| RC099V LED26S W60L60 PCV | 2600 | 29W | 12*12LEDs | 603*603*75 | | 2.6 |
| RC099V LED26S W30L120 PCV | 2600 | 29W | 6*24LEDs | 303*1203*75 | | 2.6 |
| RC099V LED26S W60L60 CPC | 2600 | 29W | 12*12LEDs | 600*600*75 | | 2.6 |
| RC099V LED26S W30L120 CPC | 2600 | 29W | 6*24LEDs | 300*1200*75 | | 2.6 |
| RC099V LED36S W60L60 | 3800 | 34W | 12*11LEDs | 597*597*75 | | 2.5 |
| RC099V LED36S W30L120 | 3800 | 34W | 6*22LEDs | 297*1197*75 | | 2.5 |
| RC099V LED36S W60L60 SUS | 3800 | 34W | 12*11LEDs | 603*603*75 | | 2.6 |
| RC099V LED36S W30L120 SUS | 3800 | 34W | 6*22LEDs | 303*1203*75 | | 2.6 |
| RC099V LED36S W60L60 PCV | 3800 | 34W | 12*11LEDs | 603*603*75 | | 2.6 |
| RC099V LED36S W30L120 PCV | 3800 | 34W | 6*22LEDs | 303*1203*75 | | 2.6 |
| RC099V LED36S W60L60 CPC | 3800 | 34W | 12*11LEDs | 600*600*75 | | 2.6 |
| RC099V LED36S W30L120 CPC | 3800 | 34W | 6*22LEDs | 300*1200*75 | | 2.6 |





W60L60




W30L120

### A Recessed 嵌入式





RC099V LED26S W60L60
RC099V LED26S W30L120
RC099V LED36S W60L60
RC099V LED36S W30L120

安装并调整好灯具位置

Adjust the luminaire position to fit ceiling well

### B 集成吊顶(CPC)



RC099V LED26S W60L60 CPC
RC099V LED26S W30L120 CPC
RC099V LED36S W60L60 CPC
RC099V LED36S W30L120 CPC

安装并调整好灯具位置

Adjust the luminaire position to fit ceiling well


PHILIPS


Philips Lighting Luminaires (Shanghai) Company
Address: 2F, Building 6, No. 1805, Huyi Highway, Malu Town, Jiading District, SH, PRC
Postalcode: 201801
飞利浦灯具（上海）有限公司
地址：中国上海市嘉定区马陆镇沪宜公路1805号6幢二层
邮编：201801

## C PCV 石膏板安装


RC099V LED26S W60L60 PCV
RC099V LED26S W30L120 PCV
RC099V LED36S W60L60 PCV
RC099V LED36S W30L120 PCV

1




石膏板开口尺寸 cutout size
W60L60：584*584mm(+/-2mm)
W30L120:284*1184mm（+/-2mm）
Ceiling thickness:2mm-16mm
天花板厚度:2mm-16mm


2




3




4




5






Suspend mount 悬吊安装




RC099V LED26S W60L60 SUS
RC099V LED26S W30L120 SUS
RC099V LED36S W60L60 SUS
RC099V LED36S W30L120 SUS

## Wiring Method
## 接线方式




Please use IP20 or above terminal box (dimension can't smaller than 10x20x25), it is not provided by Philips.
请使用IP20以上的接线盒（接线端子尺寸不小于10x20x25mm）,飞利浦不提供接线盒。

## 安全吊绳 safety cable




The product(include A、B、C 3 mounting types) should install safety chain (Safety chain is not included.).
本产品（包括A、B、C三种安装方式）需要安装安全链（本产品不含安全链）

DANGER – RISK OF FIRE

- Shall not be installed in residential premises

SCI= 25mm MIC= 25mm SCB=25mm HCB= 50mm

1. The luminaire shall be installed by a qualified electrician and wired in accordance with the latest IEE electrical regulations or the national requirements.
灯具应由有资格的电工安装，接线要符合IEE电气标准或国家标准。
2. The luminaire is complied to IEC 60598-1 ed. 6 or GB 7000.1-2007.
此灯具是依据IEC 60598-1 ed. 6 或国标GB 7000.1-2007所制造。
3. The cable of the luminaire should use "Z" type connection. The luminaire has to be scrapped if the wire broken.
灯具电源线使用Z型连接，电源线不可更换，损坏则灯具报废。
4.safety cable is necessary
必须系上安全绳
5.The luminaire shall ,under no circumstance, be covered with insulation matting or similar material.
灯具不适合被隔热衬垫或类似材料覆盖。

Building insulation abutting or within 100mm horizontally of the luminaire must meet the following requirement:
A) Be of a type that can maintain its dimensions and structural integrity when exposed to the maximum surface temperatures of the class of luminaire being 90℃.
B)Be of at type able to withstand a 30 second needle flame test carried out in accordance with AS/NZS 60695.11.5 with the flame applied to all surfaces of the test sample.

This product is not for household use.