



Philips Lighting

MANUFACTURER'S DECLARATION OF CONFORMITY

Manufacturer:

Philips Eclairage

Le Vivier

41600 LAMOTTE BEUVRON

FRANCE

Ref.: LDB-7/QDL4027.06

Date: 2006/06/14

Product (range) identification:

MBS262 1xCDM-TC/APACHE-TC 35 W IC - MBS262 1xCDM-TC/APACHE-TC 35 W IC

MBS262 1xCDM-TC/APACHE-TC 70 W EB

MBS262 1xCDM-T/APACHE-T 35 W IC - MBS262 1xCDM-T/APACHE-T 35 W EB

MBS262 1xCDM-T/APACHE-T 70 W IC - MBS262 1xCDM-T/APACHE-T 70 W EB

MBS262 1xCDM-T/APACHE-T 150 W IC - MBS262 1xCDM-T/APACHE-T 150 W EB

MBS262 1xSDW-TG/SAT-TG 100 W EB - MBS262 1xSDW-TG/SAT-TG 50 W EB

The product (range) is in conformity with the essential requirements of:

1 - Low Voltage Directive

on basis of compliance with the harmonised standard(s)

EN 60598-2-2

Recessed luminaires

2 - Electromagnetic Compatibility Directive

on basis of compliance with the harmonised standard(s)

2004/108/CE; 91/263/EEC;

92/31/EEC; 93/68/EEC

73/23/EEC; 93/68/EEC

EN 55015

Limits and methods of radio disturbance characteristics of electrical lighting

and similar equipment

EN 61547

Equipment for general lighting purpose - EMC immunity requirements

EN 61000-3-2

Limits for harmonic currents emissions (< 16A per phase)

- 3 resistant to the glow wire test of 960 °C (5 secondes)
 - the suitability for direct mounting on normally flammable surfaces



- the degree of protection IP20

- rules for equipment class I, in accordance with EN60598-1.

Additional qualifications:

- The factory is certified in accordance with the QUALITY NORM ISO 9001
 - Certificate of Registration, number 1993/995b issued by AFAQ on 2004/06/18
- The quality system in operation includes at least:
 - 100% electrical testing on both safety aspects and functioning,
 - sampling and inspection of packed products according to the production quality inspection system,
 - auditing of the production quality inspection system by the Quality Department Lighting.

Name(s) of management's representative(s):

Signature(s)

B. MAUCHIEN