



# ActiLume MicroLuxSense

## LRL1222/10 ActiLume MicroLuxSense


ActiLume MicroLuxSense is connected to the 1-10 V DC control input of the HFR ballast. ActiLume MicroLuxSense dims light down close to the minimum level of the ballast. ActiLume MicroLuxSense is calibrated for use in a standard office situation with 600 lux installed and 500 lux required.

#### **Product data**

| Product Data        |                                   |
|---------------------|-----------------------------------|
| Order product name  | LRL1222/10 ActiLume MicroLuxSense |
| Full product name   | LRL1222/10 ActiLume MicroLuxSense |
| Full product code   | 871829115238500                   |
| Order code          | 913700346403                      |
| Material Nr. (12NC) | 913700346403                      |

| Numerator - Quantity Per Pack   | 1             |
|---------------------------------|---------------|
| EAN/UPC - Product/Case          | 8718291152385 |
| Numerator - Packs per outer box | 1             |
| EAN/UPC - Case                  | 8718291152392 |
|                                 |               |

## Dimensional drawing




#### Product


LRL1222/10 ActiLume MicroLuxSense

Datasheet, 2023, April 30 data subject to change

## **ActiLume MicroLuxSense**

## Dimensional drawing





#### Product

LRL1222/10 ActiLume MicroLuxSense



© 2023 Signify Holding All rights reserved. Signify does not give any representation or warranty as to the accuracy or completeness of the information included herein and shall not be liable for any action in reliance thereon. The information presented in this document is not intended as any commercial offer and does not form part of any quotation or contract, unless otherwise agreed by Signify. Philips and the Philips Shield Emblem are registered trademarks of Koninklijke Philips N.V.