
Revised: 11/12/2012


PHILIPS ADVANCE

e-Vision[®] Electronic Ballast for Metal Halide Lamps Catalog Number: IMH-70-A-BLS-ID For 70W Metal Halide Lamps ANSI C98/M98, C139/M139 or M143 120-277 50/60Hz Electronic Status: RELEASED

DIMENSIONS AND DATA


Lamp				Line	Input	Min			Weight	Max.	
		Input		Current	Power	Power	Wiring Diag	Fig.	(lb)	Distance to	
Number	Watts	Volts	Catalong Number*	(Amps)	(Watts)	Factor			(10)	Lamp (ft)	
70W Watt Lamp, ANSI Code C98/M98, C139/M139 or M143 Minimum Starting Temp -20°C/-4°F											
1	70	120	IMH-70-A-XXX-ID	0.72	86	0.9	8	A/B	1.6	6	
		277		0.31	84						





Case Figure	Overall Length	Case Length	Case Width	Height	Mountin Length	Mounting Width
A/B	140mm	120mm	92mm	38mm	132mm	73mm
	[5.5"]	[4.7"]	[3.6"]	[1.5"]	[5.2"]	[2.9"]

Ballast will not operate if Insulation Detector is Absent, Shorted or Failed Open







INSTALLATION & APPLICATION NOTES:

- Maximum allowable case temperature is 90°C.
 See figure above for measurement location
- 2. Ignition pulse is 4 kV max
- 3. All leads are 12 inches long
- 4. Ballast output will shutdown after 20 minutes if lamp fails to ignite
- 5. Power must be cycled off then on, after replacing lamp
- Use with any Self Heating Thermal Protector (Insulation Detector) having equivalent resistive value 5k to 25k ohm (4 wire versions only)
- 7. Open Circuit voltage across ID output approx 270VDC

*Ordering Information

Order Suffix Description

-BLS Ballast with bottom exit leads and mounting studs

Data is based on tests performed by Philips Advance in a controlled environment and is representative of relative performance. Actual performance can vary depending on operating conditions. Specifications are subject to change without notice. All specifications are nominal unless otherwise noted.