



TYPE:









Complete Fixture con	sists of FRAME-IN KIT & REFLECTOR TRIM. Select each separately.
	Frame In Kit — See Individual Frame In Kit Specification Sheets

Reflector Trim			Fra	ame-In Kit — S	-rame-In Kit Spe	ne-In Kit Specification Sheets				
			Incande	scent		Fluorescent				
		Frame-In Kit	Installation Type	Lamping	Height	Frame-In Kit	Installation Type	Lamping	Height	
		□ 1002P1	Non-IC		7 1/8"	□ 1002F1	Non-IC	1 Lamp Quad Tube	6 7/8"	
<b>□ 1085</b> Peri	Perma White	□ 1003R	Non-IC Remodeler	60W A19	7 1/8"	☐ 1002FH1	Non-IC	13W (GX23-2)	6 7/8"	
						□ 1002FH2	Non-IC		6 7/8"	
		□ 1000IC	IC		7 5/16"	☐ 1002FH1R	Non-IC Remodeler		6 7/8"	
		□ 1000AICM	IC	40W A19	7 5/16"	☐ 1910XFH1	Conversion		6 7/8"	
		□ 1004ICX/N	IC		7 1/4"					
		□ 1004IC/N	Non-IC		7 1/2"					
		□ 1004ICR	Non-IC Remodeler	40W A19	7 1/2"					
		□ 1004SIC/N	Non-IC		7 1/4"					
		□ 1004SICR	Non-IC		7 1/4"					
		1	1	1	1					

#### Features

- 1. Reflector: Hydroformed aluminum, .040" thick (18 ga.) yellowing resistant, scuff resistant Perma White finish, 88% reflectance; provides smooth wash of light over wall surface without scallops or shadows; white trim flange.
- 2. Aperture Plate: Molded high heat polymer white finish.
- 3. Frame-In Kit: (1002P1 standard frame shown). Other frames listed above and shown on the right. See Frame-In Kit specification sheets for more details.

# **Options & Accessories**

7" 0.D **Extra Wide Flange Trim Ring:** 1957 -

Extra Thick Ceiling Mounting Rings: 1967B - up to 2" thick ceiling

# Labels

UL (Suitable for Damp Locations); I.B.E.W.; U.S. Patent Numbers: 4,313,154; 4,327,403; 4,751,624; 5,045,985 Other U.S. & Foreign Patents Pending

WE RESERVE THE RIGHT TO CHANGE DETAILS OF DESIGN, MATERIALS, AND FINISH.

LIGHTOLIER a GENLYTE THOMAS company. 631 Airport Road, MA 02720 (508) 679-8131 • Fax (508) 674-4710

Copyright 2001

### **LIGHTING DATA**

EXAMPLE: Multiple 60W A19 units, located 2' from wall and 2' on center, provided illumination on the wall 3' down from the ceiling of 10 f.c. beneath and 10 f.c. between the fixtures.

### **FOOTCANDLES ON WALL FROM MULTIPLE UNITS**

						60W A19			
	UNITS 2 FEET FROM WALL								
ᇤ			Ь_	- 2' -	<u> </u>	<u>р</u>	<b>–</b> 3' -	_	
LING,	1 2		9	8 11	9	6 8	5 7	6 8	
M CEI	3 4		[10] 8	[10] 8	[10] 8	7 6	7 6	7 6	
DISTANCE FROM CEILING, FT	5 6		6 4	5 4	6	4 3	4 3	4	
TANC	7 8		3 2	3 2	3 2	2 2	2 2	2	
Sia	9		2	1	2	. 1	1	1	

						<b>V</b> Quad Tube			
	UNITS 2 FEET FROM WALL								
E.			Ь-	- 2' -	_	П	— 3' ·	_	
LING,	1 2		6 10	5 10	6 10	5 7	3 6	5 7	
MCE	3 4		8	8	8	6 4	5 4	6 4	
8.3	5 6		4	4 2	4	3 2	3	3 2	
DISTANCE FROM CEILING, FT	7 8		2 1	2	2 1	1 1	1	1	
l Si	9		1	1	1	1	1	1	

Footcandle values are averaged and rounded off and are based on a minimum of five units.

For fixture-to-wall distance, other than those shown, use maximum of 1 of 1 spacing (distance between fixtures not more than distance to wall) for best results. To convert lighting data for a lower wattage incandescent lamp of the **same type**, multiply the footcandle values by the ratio of the lumens of the two lamps.