


INSTALLATION INSTRUCTIONS

300 LINE CYLINDERS – WALL MOUNT

IMPORTANT: READ ALL INSTRUCTIONS BEFORE PERFORMING ANY WORK.
BE SURE ALL POWER IS OFF PRIOR TO INSTALLING LUMINAIRE.

WARNING: LUMINAIRE MUST BE GROUNDED IN ACCORDANCE WITH APPROPRIATE CODES. FAILURE TO DO SO MAY RESULT IN SERIOUS INJURY.




NOTE: MOUNTING BRACKET IS SECURED TO WALL WITH 5/16 BOLTS (BY OTHERS). STRUCTURAL MEMBERS MUST BE PRESENT IN WALL TO ACCEPT BOLTS.

3. MAKE ELECTRICAL CONNECTIONS. FIXTURE LINE TO SUPPLY LINE, COMMON TO COMMON AND GROUND TO GROUND.

4. PLACE SPLICES AND EXCESS WIRE IN SPLICE BOX. CAREFULLY ENGAGE HANGER BRACKET TO MOUNTING BRACKET BEING CAREFUL NOT TO PINCH WIRES. ALLOW FIXTURE TO REST AGAINST WALL. TIGHTEN LOCKING SCREWS.

1. APPLY A BEAD OF SEALANT ON WALL AROUND SPLICE BOX OPENING AND AROUND MOUNTING HOLES. WHEN USING A FOUR INCH SQUARE BOX (SHOWN), FILL GAP BETWEEN WALL OPENING AND SPLICE BOX WITH SEALANT. APPLY SEALANT TO THE TOP INSIDE CORNERS OF THE MOUNTING BRACKET AND TO THE THREE UNUSED HOLES IN THE TOP ANGLED FLAP OF THIS BRACKET.
2. PLACE MOUNTING BRACKET OVER SPLICE BOX AND SECURE TO WALL WITH 5/16 BOLTS (BY OTHERS). NOTE: SPLICE BOX SCREWS MAY BE USED TO HOLD THE MOUNTING BRACKET IN PLACE WHILE THE BOLTS ARE BEING INSTALLED.



MOUNTING BOLT PATTERN

PHILIPS

© 2016 Philips Lighting Holding B.V. All rights reserved.

A815676/443561004410-A

1 OF 2

INSTALLATION INSTRUCTIONS

300 LINE CYLINDERS – WALL MOUNT

IMPORTANT: READ ALL INSTRUCTIONS BEFORE PERFORMING ANY WORK.
BE SURE ALL POWER IS OFF PRIOR TO INSTALLING LUMINAIRE.

WARNING: LUMINAIRE MUST BE GROUNDED IN ACCORDANCE WITH APPROPRIATE
CODES. FAILURE TO DO SO MAY RESULT IN SERIOUS INJURY.

5. IN LENSED UNITS, REMOVE LENS
ASSEMBLY IF LAMP INSTALLATION IS
REQUIRED. INSTALL LAMP AND REPLACE
LENS ASSEMBLY. (TYPICAL LENS
ASSEMBLIES ARE SHOWN FOR
REFERENCE ONLY)

NOTE: ALL WALL MOUNTED 300 LINE
CYLINDERS ARE WET LOCATION RATED.
DOWNLIGHT CYLINDERS MAY BE MOUNTED
INVERTED IN DAMP LOCATIONS.
UPLIGHT CYLINDERS MAY BE MOUNTED
INVERTED IN WET LOCATIONS EXCEPT
THOSE WITH FORWARD THROW (FT/C) OPTICS.

