Fugato Micro Cardanic

MBS244/LBS244

Installation instruction/ 安装说明

4441 000 64971a


F | GB 7000 | IEC 60598 | IP20


Micro Ø97mm	MBS244	PGJ5	CDM-Tm 20/35W	⏚	Ø73×3 heat strengthen glass	0.40(20W) 0.67(35W)
	LBS244	GY6.35	HAL-C max.50W	▣	Ø73×3 钢化玻璃	0.35


Replace any cracked safety screen
请及时更换破损安全玻璃

Disconnect the unit before changing the lamp
更换灯泡前请切断电源

Minimum distance between lamp and any combustible materials : see symbol on luminaire
到被照物最短距离（m）见灯体标示









Philips Lighting Luminaires (Shanghai) Co., Ltd.
Address: No. 2688, Huyi Road, Jiading, Shanghai, China
Postalcode: 201801


飞利浦灯具（上海）有限公司
中国上海市嘉定区马陆镇沪宜公路2688号
邮编：201801

PHILIPS






MBS244 20W




MBS244 35W




LBS244 max. 50W

A




2×0.5～0.75 mm²


B




C




D




E






MBS244



LBS244



1. The luminaire shall be installed by a qualified electrician and wired in accordance with the latest IEE electrical regulations or the national requirements.
   灯具应由有资格的电工安装，接线要符合IEE 电气标准或国家标准。
2. The luminaire shall, under no circumstance,be covered with thermal insulation matting or similar material.
   灯具不适合被隔热或类似材料覆盖。
3. The luminaire shall only be used complete with its protective shield.
   灯具应只能完整地带有保护屏使用。