F-can (72C)

F-CAN HID MH BAL 150W M81 120/277V FCAN

The Philips Advance line of F-can HID ballasts comes in two dual-voltage configurations for the US and Canadian market. Ballasts for these luminaires are most often encased and potted in fluorescent ballast type cans.

Product data

General Information

ANSI Code	M81(PULSESTART)
Lamp Type	150W MH
Number of Lamps	1 piece/unit
Circuit Type	HX-HPF
Ballast Type	Magnetic HID
Base Model	72C5481
Suitable For Outdoor Use	Yes
Ignitor Catalog Number	Inside Can
Capacitor Catalog Number	Inside Can
Automatic Restart	No

Operating and Electrical

Input Voltage	120/277 V
Input Frequency	60 Hz
Inp. Current (Open Circuit)	3.65/1.6 A
Input Current (Starting)	1.75/0.75 A
Input Current (Short Circuit)	1-1.5/0.4-0.65 A
Secondary Short Circuit Current	2.15-2.65 A
Constant Wattage Deviation	12%
Ballast Factor (Nom)	1
Power Factor (Nom)	0.90
Nominal Open Circuit Voltage	240 V
Input Current (Operating) (Nom)	1.6/0.7 A A

Input Power (Nom)	180 W
Rated Lamp Watts	150 W

Wiring

Wire Striplength	0.5 mm
Wire Length by Color	12"
Wire Type	Stranded
Remote Wiring Configuration Allowed	Yes
Max Ballast-Lamp Distance Remote Wiring	10'
Recommended Fuse Value	10/4 A

Mechanical and Housing

Housing Material	Metal
Housing	F-Can
Housing Dimensions	14.3 x 2.63 x 3.19

Approval and Application

|	
Open Circuit Voltage Test (Volts)	215-265 V
Approbation Marks	CSA certificate UL certificate RoHS Compliant
Temperature Marking	90ºC max. case
UL Recognized	No
Hipot Test (1 Minute)	1600 V
Hipot Test (2 Seconds)	2000 V

F-can (72C)

UL Insulation Class	A(105°C)
UL Temperature Code	NA

Product Data	
Order product name	F-CAN HID MH BAL 150W M81 120/277V FCAN
EAN/UPC – Product	781087254813

Order code	72C5481NP
Numerator – Quantity Per Pack	1
Numerator – Packs per outer box	4
Material Nr. (12NC)	913700580009
Net Weight (Piece)	5.630 kg

Dimensional drawing

MH BAL 150W M81 120/277V FCAN

Product	A1	A2	A3	B1	B2	C1	D1
F-CAN HID 72C5481NP	12 in	13.75 in	13.13 in	3.9 in	2.0 in	2.6 in	0.3 in

www.lighting.philips.com

2019, February 12 – data subject to change